

T E S T C E R T I F I C A T E

CT-23-03-13-05

Product: Three layer board 60 mm
Nominal thickness range: 14 – 60 mm
Gluing: MUF glued

Customer: TILLY Holzindustrie Gesellschaft m.b.H
Krappfelder Straße 27
9330 Althofen
Austria

Order: Accomplishment of an emission test regarding VOC and Formaldehyde according to DIN EN 16516 (10/2020) and evaluation according to AgBB-Scheme, French VOC- and CMR-regulation and baubook

Test report: 2522576/2 dated 13/03/2023

Test results: The tested product „Three layer board“ meets the requirements of the AgBB-Scheme 2018 and 2021 and also the criteria according to baubook.
Furthermore, it meets the requirements regarding French regulation Category A. The French CMR regulation is fulfilled.

Dresden, 13/03/2023



Head of laboratory



Engineer in charge